

# Capay Dam Daily Rediversions

Month: **July**      **2024**

## WINTERS CANAL

Day	RATING	FLOW	DIFF.	%
	CURVE	METER		
	(CFS)	AVERAGE		
		(CFS)		
1	348.85	334.27	14.58	4.2%
2	378.03	368.85	9.18	2.4%
3	428.21	420.60	7.61	1.8%
4	424.47	420.07	4.4	1.0%
5	411.18	403.28	7.9	1.9%
6	407.99	403.48	4.51	1.1%
7	426.34	427.15	-0.81	-0.2%
8	427.48	431.27	-3.79	-0.9%
9	435.74	443.77	-8.03	-1.8%
10	434.22	439.99	-5.77	-1.3%
11	434.27	441.41	-7.14	-1.6%
12	437.48	434.71	2.77	0.6%
13	436.16	438.92	-2.76	-0.6%
14	438.12	436.86	1.26	0.3%
15	436.66	433.60	3.06	0.7%
16	419.24	416.09	3.15	0.8%
17	418.37	411.12	7.25	1.7%
18	392.39	384.56	7.83	2.0%
19	395.70	386.84	8.86	2.2%
20	354.01	349.44	4.57	1.3%
21	332.88	335.49	-2.61	-0.8%
22	351.46	351.03	0.43	0.1%
23	346.08	350.78	-4.7	-1.4%
24	371.14	381.06	-9.92	-2.7%
25	375.60	387.97	-12.37	-3.3%
26	383.92	396.46	-12.54	-3.3%
27			0	#DIV/0!
28			0	#DIV/0!
29			0	#DIV/0!
30			0	#DIV/0!
31			0	#DIV/0!

## WEST ADAMS CANAL

Day	RATING	FLOW	DIFF.	%
	CURVE	METER		
	(CFS)	AVERAGE		
		(CFS)		
1	245.11	229.22	15.89	6.5%
2	267.14	257.80	9.34	3.5%
3	252.33	234.07	18.26	7.2%
4	254.22	242.10	12.12	4.8%
5	275.77	276.08	-0.31	-0.1%
6	267.65	259.99	7.66	2.9%
7	242.70	226.39	16.31	6.7%
8	244.53	231.08	13.45	5.5%
9	274.86	272.15	2.71	1.0%
10	267.00	258.41	8.59	3.2%
11	272.70	262.42	10.28	3.8%
12	250.52	233.41	17.11	6.8%
13	248.88	220.30	28.58	11.5%
14	237.13	218.87	18.26	7.7%
15	250.47	232.27	18.2	7.3%
16	263.31	236.75	26.56	10.1%
17	253.46	217.06	36.4	14.4%
18	261.53	227.36	34.17	13.1%
19	259.63	222.54	37.09	14.3%
20	247.36	215.62	31.74	12.8%
21	234.50	215.20	19.3	8.2%
22	239.03	219.59	19.44	8.1%
23	232.97	218.38	14.59	6.3%
24	225.41	211.23	14.18	6.3%
25	226.52	210.24	16.28	7.2%
26	217.64	197.79	19.85	9.1%
27			0	#DIV/0!
28			0	#DIV/0!
29			0	#DIV/0!
30			0	#DIV/0!
31			0	#DIV/0!

## HQ PRECIPITATION

Day	SCADA	MANUAL
	READING	READING
	(INCHES)	(INCHES)
1	0	0
2	0	0
3	0	0
4	0	
5	0	0
6	0	
7	0	
8	0	0
9	0	0
10	0	0
11	0	0
12	0	0
13	0	
14	0	
15	0	0
16	0	0
17	0	0
18	0	0
19	0	0
20	0	
21	0	
22	0	0
23	0	0
24	0	0
25	0	0
26		0
27		
28		
29		
30		
31		

Diversions are based on 0600 readings

Precipitation: SCADA reading is at midnight each day, Manual reading is at 0700 each morning