

DAILY DAM OPERATIONAL DATA

INDIAN VALLEY RESERVOIR, NORTH FORK OF CACHE CREEK

Gross Storage: 300,600 AF Spillway crest: 1463ft. MSL			***DAILY READINGS ARE ON MIDNIGHT TO MIDNIGHT BASIS***										MONTH: JUNE
			YEAR: 2025										
Day	Pool Elevation (MSL)	Storage (AF)	Mean In (CFS)	Mean Out (CFS)	Precip. @ Dams (In)		Hydro Unit #1		Hydro Unit #2		Hydro Unit #3		
					IV	CCK	CFS	TIME RESET	CFS	TIME RESET	CFS	TIME RESET	COMMENTS
1	1472.23	251,297	16	430	0.00	0.00	123		124				401cfs SCADA - at 1100 No Change
2	1471.98	250,328	-58	431	0.00	0.00	121		122				401cfs SCADA - at 1100 No Change
3	1471.78	249,608	66	430	0.00	0.00	125		125				401cfs SCADA - at 1100 No Change
4	1471.52	248,672	-40	433	0.00	0.00	128		129				400cfs SCADA - at 1100 No Change
5	1471.31	247,916	48	430	0.00	0.00	124		125				402cfs SCADA - at 1100 No Change
6	1471.09	247,124	30	430	0.00	0.00	127		128				403cfs SCADA - at 1100 No Change
7	1470.86	246,296	12	430	0.00	0.00	127		128				400cfs SCADA - at 1100 No Change
8	1470.65	245,540	49	431	0.00	0.00	127		128				402cfs SCADA - at 1100 No Change
9	1470.42	244,712	13	431	0.00	0.00	128		128				406cfs SCADA - at 1100 No Change
10	1470.19	243,884	12	430	0.00	0.00	127		128				408cfs SCADA - at 1100 No Change
11	1469.95	243,020	-6	430	0.00	0.00	124		124				406cfs SCADA - at 1100 No Change
12	1469.69	242,084	-44	429	0.00	0.00	127		128				404cfs SCADA - at 1100 No Change
13	1469.46	241,256	10	428	0.00	0.00	128		128				405cfs SCADA - at 1100 No Change
14	1469.23	240,428	10	428	0.00	0.00	127		127				407cfs SCADA - at 1100 No Change
15	1468.94	239,384	-96	431	0.00	0.00	129		129				403cfs SCADA - at 1100 No Change - USGS reading 1475.2
16	1468.74	238,664	67	431	0.00	0.00	129		130				407cfs SCADA - at 1100 No Change
17	1468.53	237,908	19	401	0.00	0.00	128		129				405cfs SCADA - at 1000 cut 50cfs
18	1468.32	237,152	0	382	0.00	0.00	126		127				359cfs SCADA - at 1100 No Change
19	1468.09	236,324	-36	382	0.00	0.00	126		126				356cfs SCADA - at 1100 No Change
20	1467.86	235,496	-38	380	0.00	0.00	125		125				354cfs SCADA - at 1100 No Change
21	1467.63	234,668	-39	379	0.00	0.00	127		127				356cfs SCADA - at 1100 No Change
22	1467.43	233,948	5	369	0.00	0.00	127		127				358cfs SCADA - at 1100 No Change
23	1467.22	233,192	-14	368	0.00	0.00	126		126				354cfs SCADA - at 1100 No Change
24			0										
25			0										
26			0										
27			0										
28			0										
29			0										
30			0										
31			0										
Sum			-29.939	9114	0.00	0.00							