

DAILY DAM OPERATIONAL DATA

CACHE CREEK DAM BELOW CLEAR LAKE

Storage: 313,000 AF 0' on RG: 1318.25' MSL			***DAILY READINGS ARE ON MIDNIGHT TO MIDNIGHT BASIS***						MONTH: October
									YEAR: 2025
Day	Rumsey	Storage (AF)	Available (AF)	Mean In (CFS)	Mean Out (CFS)	Precip. (In)	Hydro Plant		Comments
	Gauge (Ft.)					C. Ck. Dam	Turbine (CFS)	Time Reset	
1	3.08	124,494	42,547	255	255	0.10			294cfs SCADA - at 1100 cut 20cfs
2	3.03	122,442	42,056	-789	248	0.00			275cfs SCADA - at 1100 No Change
3	3.00	121,210	41,616	-400	222	0.02			276cfs SCADA - at 1100 -50cfs
4	2.99	120,800	41,218	-6	201	0.00			227cfs SCADA - at 1100 No Change
5	2.98	120,389	40,824	-8	199	0.00			227cfs SCADA - at 1100 No Change
6	2.95	119,158	40,401	-408	214	0.00			225cfs SCADA - at 1100 inc 20cfs - at 1615 inc15cfs
7	2.92	117,926	39,904	-371	251	0.00			261cfs SCADA - at 1300 inc 40cfs
8	2.89	116,695	39,375	-355	267	0.00			297cfs SCADA - at 1100 No Change
9	2.88	116,284	38,850	58	265	0.00			297cfs SCADA - at 1100 No Change
10	2.84	114,642	38,585	-695	134	0.00			294cfs SCADA - at 1100 cut 75cfs-at 1215 cut 75cfs-at 1300 cut 75cfs-at 1500 cut to 5cfs End of irrigation season
11	2.82	113,821	38,576	-410	4.39	0.00			8cfs SCADA
12	2.80	113,000	38,568	-411	4.10	0.00			7cfs SCADA
13	2.83	114,232	38,561	626	3.74	0.56			6cfs SCADA
14	2.86	115,463	38,554	625	3.39	0.24			6cfs SCADA
15	2.86	115,463	38,547	3	3.37	0.03			6cfs SCADA
16	2.83	114,232	38,541	-619	3.31	0.00			5cfs SCADA
17	2.83	114,232	38,535	3	3.14	0.00			5cfs SCADA
18	2.82	113,821	38,529	-205	2.77	0.00			5cfs SCADA
19	2.81	113,411	38,524	-205	2.69	0.00			5cfs SCADA
20	2.81	113,411	38,519	3	2.67	0.00			5cfs SCADA
21	2.80	113,000	38,514	-205	2.49	0.00			5cfs SCADA
22		0	0	0					
23		0	0	0					
24		0	0	0					
25		0	0	0					
26		0	0	0					
27		0	0	0					
28		0	0	0					
29		0	0	0					
30		0	0	0					
31		0	0	0					
Sum				-3,513	2,292.06	0.95			