

DAILY DAM OPERATIONAL DATA
INDIAN VALLEY RESERVOIR, NORTH FORK OF CACHE CREEK

Gross Storage: 300,600 AF Spillway crest: 1463ft. MSL			***DAILY READINGS ARE ON MIDNIGHT TO MIDNIGHT BASIS***										MONTH: JUNE	
													YEAR: 2026	
Day	Pool Elevation (MSL)	Storage (AF)	Mean In (CFS)	Mean Out (CFS)	Precip. @ Dams (In)		Hydro Unit #1		Hydro Unit #2		Hydro Unit #3		COMMENTS	SPILLWAY DISCHARGE
					IV	CCK	CFS	TIME RESET	CFS	TIME RESET	CFS	TIME RESET		
1	1472.84	253,676	-37	239	0.00	0.00	111		112				234cfs SCADA - at 1100 no change	4.04
2	1472.71	253,169	-19	237	0.00	0.00	114		113				234cfs SCADA - at 1100 no change	7.49
3	1472.58	252,662	-19	237	0.00	0.00	115		115				232cfs SCADA - at 1100 no change	NR
4	1472.45	252,155	-20	236	0.00	0.00	113		114				235cfs SCADA - at 1100 no change	NR
5	1472.30	251,570	-58	237	0.00	0.00	113		113				233cfs SCADA - at 1100 no change	5.19
6	1472.16	251,024	-36	240	0.00	0.00	113		114				233cfs SCADA - at 1100 no change	5.50
7	1472.02	250,478	-33	243	0.00	0.00	114		115				232cfs SCADA - at 1100 no change	5.11
8	1471.87	249,932	-40	236	0.00	0.00	113		114				234cfs SCADA - at 1100 no change	4.70
9	1471.75	249,500	19	237	0.00	0.00	113		113				232cfs SCADA - at 1100 no change	4.46
10	1471.63	249,068	18	236	0.00	0.00	112		113				233cfs SCADA - at 1100 no change	NR
11	1471.46	248,456	-73	236	0.00	0.00	113		114				236cfs SCADA - at 1100 no change	NR
12	1471.33	247,988	-73	239	0.00	0.00	115		115				234cfs SCADA - at 1100 no change	4.71
13	1471.19	247,484	-15	240	0.00	0.00	113		114				234cfs SCADA - at 1100 no change	4.30
14	1471.05	246,980	-14	241	0.00	0.00	114		115				236cfs SCADA - at 1100 no change	4.16
15	1470.92	246,512	8	244	0.00	0.00	115		114				235cfs SCADA - at 1100 no change	6.38
16	1470.79	246,044	5	241	0.00	0.00	115		115				238cfs SCADA - at 1100 no change	10.82
17	1470.64	245,504	-32	241	0.00	0.00	115		115				235cfs SCADA - at 1100 no change	NR
18	1470.49	244,964	-31	242	0.00	0.00	114		112				236cfs SCADA - at 1100 no change	NR
19	1470.34	244,424	-33	240	0.00	0.00	114		114				234cfs SCADA - at 1100 no change	8.90
20	1470.21	243,959	7	242	0.00	0.00	115		115				242cfs SCADA - at 1100 no change	6.20
21	1470.07	243,452	-14	242	0.00	0.00	115		116				242cfs SCADA - at 1100 no change	7.63
22	1469.91	242,876	-52	239	0.00	0.00	115		116				240cfs SCADA - at 1100 no change	NR
23	1469.76	242,336	-35	238	0.00	0.00	116		118				238cfs SCADA - at 1100 no change	3.05
24	1469.61	241,796	-16	257	0.00	0.00	115		116				238cfs SCADA - at 1100 no change	
25	1469.42	241,220	-38	253	0.00	0.00	113		114				238cfs SCADA - at 1100 no change	
26			0											
27			0											
28			0											
29			0											
30			0											
31			0											
Sum			-592.45	5,774.00	0.00	0.00								