

DAILY DAM OPERATIONAL DATA

INDIAN VALLEY RESERVOIR, NORTH FORK OF CACHE CREEK

Gross Storage: 300,600 AF Spillway crest: 1463ft. MSL			***DAILY READINGS ARE ON MIDNIGHT TO MIDNIGHT BASIS***										MONTH: JULY	
													YEAR: 2026	
Day	Pool Elevation (MSL)	Storage (AF)	Mean In (CFS)	Mean Out (CFS)	Precip. @ Dams (In)		Hydro Unit #1		Hydro Unit #2		Hydro Unit #3		COMMENTS	SPILLWAY DISCHARGE
					IV	CCK	CFS	TIME RESET	CFS	TIME RESET	CFS	TIME RESET		
1	1468.52	237,872	-35	256	0.00	0.00	116		116				238cfs SCADA - at 1100 no change	NR
2	1468.37	237,332	-17	256	0.00	0.00	116		117				237cfs SCADA - at 1100 no change	19.44
3	1468.35	237,260	221	257	0.00	0.00	116		117				240cfs SCADA - at 1100 no change	17.44
4	1468.24	236,864	59	259	0.00	0.00	116		116				239cfs SCADA - at 1100 no change	16.68
5	1468.06	236,216	-67	260	0.00	0.00	116		115				242cfs SCADA - at 1100 no change	14.84
6	1467.94	235,784	42	260	0.00	0.00	117		117				242cfs SCADA - at 1100 no change	14.75
7	1467.79	235,244	-13	260	0.00	0.00	118		118				242cfs SCADA - at 1100 no change	12.36
8	1467.55	234,380	-176	260	0.00	0.00	118		118				241cfs SCADA - at 1100 no change	NR
9	1467.40	233,840	-13	260	0.00	0.00	118		118				241cfs SCADA - at 1100 no change	NR
10	1467.25	233,300	-12	261	0.00	0.00	117		118				242cfs SCADA - at 1100 no change	14.58
11	1467.10	232,760	-12	261	0.00	0.00	118		118				243cfs SCADA - at 1100 no change	15.69
12	1466.95	232,220	-11	262	0.00	0.00	117		117				244cfs SCADA - at 1100 no change	15.36
13	1466.80	231,680	-11	262	0.00	0.00	117		116				242cfs SCADA - at 1100 no change	18.29
14	1466.65	231,140	-11	262	0.00	0.00	117		118				242cfs SCADA - at 1100 no change	17.69
15	1466.48	230,528	-47	262	0.00	0.00	117		118				243cfs SCADA - at 1100 no change	NR
16	1466.32	229,952	-29	262	0.00	0.00	119		120				242cfs SCADA - at 1100 no change	NR
17	1466.17	229,412	-10	263	0.00	0.00	116		117				237cfs SCADA - at 1100 no change	17.96
18	1466.00	228,800	-46	263	0.00	0.00	118		118				244cfs SCADA - at 1100 no change	17.05
19	1465.85	228,290	5	263	0.00	0.00	119		119				237cfs SCADA - at 1100 no change	18.64
20	1465.70	227,780	5	263	0.00	0.00	118		118				243cfs SCADA - at 1100 no change	13.94
21	1465.50	227,100	-77	266	0.00	0.00	119		119				248cfs SCADA - at 1100 no change	16.34
22	1465.34	226,556	-9	266	0.00	0.00	118		119				245cfs SCADA - at 1100 no change	NR
23	1465.18	226,012	-10	265	0.00	0.00	118		119				249cfs SCADA - at 1100 no change	NR
24			0											
25			0											
26			0											
27			0											
28			0											
29			0											
30			0											
31			0											
Sum			-236.90	5,753	0.00	0.00								