

DAILY DAM OPERATIONAL DATA

INDIAN VALLEY RESERVOIR, NORTH FORK OF CACHE CREEK

Gross Storage: 300,600 AF Spillway crest: 1463ft. MSL			***DAILY READINGS ARE ON MIDNIGHT TO MIDNIGHT BASIS***										MONTH: August	
													YEAR: 2026	
Day	Pool Elevation (MSL)	Storage (AF)	Mean In (CFS)	Mean Out (CFS)	Precip. @ Dams (In)		Hydro Unit #1		Hydro Unit #2		Hydro Unit #3		COMMENTS	SPILLWAY DISCHARGE
					IV	CCK	CFS	TIME RESET	CFS	TIME RESET	CFS	TIME RESET		
1	1463.73	221,082	-7	268	0.00	0.00	113		114				244cfs SCADA - at 1100 no change	16.90
2	1463.57	220,538	-6	269	0.00	0.00	113		114				247cfs SCADA - at 1100 no change	17.67
3	1463.41	219,994	-6	269	0.00	0.00	123		124				247cfs SCADA - at 1100 no change	17.63
4	1463.26	219,484	11	269	0.00	0.00	125		125				245cfs SCADA - at 1100 no change	16.94
5	1463.09	218,906	-22	270	0.00	0.00	123		124				250cfs SCADA - at 1100 no change	NR
6	1462.93	218,362	-5	270	0.00	0.00	122		123				247cfs SCADA - at 1100 no change	NR
7	1462.77	217,818	-4	271	0.00	0.00	125		125				250cfs SCADA - at 1100 no change	17.84
8	1462.61	217,274	-3	272	0.00	0.00	124		125				250cfs SCADA - at 1100 no change	NR
9	1462.45	216,730	-2	273	0.00	0.00	126		126				250cfs SCADA - at 1100 no change	NR
10	1462.28	216,152	-18	274	0.00	0.00	125		124				252cfs SCADA - at 1100 no change	NR
11	1462.11	215,574	-17	275	0.00	0.00	126		126				252cfs SCADA - at 1100 no change	NR
12	1461.94	214,996	-5	287	0.00	0.00	125		126				253cfs SCADA - at 1100 inc 25cfs	NR
13	1461.76	214,384	-13	296	0.00	0.00	125		126				270cfs SCADA - at 1100 no change	NR
14	1461.58	213,772	-13	296	0.00	0.00	126		127				269cfs SCADA - at 1100 no change	NR
15	1461.41	213,194	-9	283	0.00	0.00	125		126				274cfs SCADA - at 1100 cut 20cfs	16.73
16	1461.25	212,650	0	275	0.00	0.00	125		125				252cfs SCADA - at 1100 no change	11.01
17	1461.08	212,072	-31	261	0.00	0.00	126		126				254cfs SCADA - at 1100 no change	9.99
18	1460.92	211,528	-14	261	0.00	0.00	126		126				259cfs SCADA - at 1100 no change	11.36
19	1460.74	210,916	-48	261	0.00	0.00	125		126				255cfs SCADA - at 1100 no change	NR
20	1460.58	210,372	-14	261	0.00	0.00	126		127				253cfs SCADA - at 1100 no change	NR
21			0											
22			0											
23			0											
24			0											
25			0											
26			0											
27			0											
28			0											
29			0											
30			0											
31			0											
Sum			-216.09	5,193	0.00	0.00								